Date : 09-09-2025

To,

The Principal

Heritage Xperiential Learning School- sector 62

Gurgaon, Haryana

Respected Ma'am/Sir,

The test reports for the Water samples collected from the campus of Heritage Xperiential Learning School- sector 62 Gurgaon, Haryana are enclosed with this letter. The table below contains the details of the samples collected and the summary of the test results.

S.No.	Item	Place	BCMS Test Slip No	Sample Collected Date	Result
1	Drinking Water	SP - 2	SYS0986	02-09-2025	Sample Ok
2	Drinking Water	SP - 1	SYS0987	02-09-2025	Sample Ok
3	Drinking Water	MP	SYS0988	02-09-2025	Sample Ok
4	Drinking Water	Borewell (RAW Water)	SYS0989	02-09-2025	Sample Ok
5	Drinking Water	JP	SYS0990	02-09-2025	Sample Ok
6	Drinking Water	Canteen	SYS0991	02-09-2025	Sample Ok

Thanking You.

Authorised Signatory,

Blue Circle Medi Services Pvt. Ltd

Encl. : 1. The Scan Copy of test reports from the test lab

Blue Circle Medi Services Pvt. Ltd.

J-32, Sarita vihar, New Delhi-110076, Ph: 011-41402320, E-mail: info@bluecircle.in

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903093

FOOD SERVICES
TEST REPORT

CLIENT/ISSUED TO	ANALYSIS REPORT NO.	IFS-250903093
Blue Circle Medi Services Pvt Ltd.	REPORT ISSUE DATE:	08/09/2025
J-33, Sarita Vihar	YOUR REF:	TRF
New Delhi-76	DATED:	02/09/2025
	ULR NO:	TC643425000035247F

PRODUCT GROUP:	Water

DETAILS PROVIDED BY CUSTOMER:	
NAME OF THE PRODUCT	Drinking Water
SAMPLE DETAILS	Sample code: SYS0986, Sampling Point: SP-2
TEST REQUIRED	Chemical and Biological Test
ANY OTHER INFORMATION	N/A

LAB INFORMATION:			
SAMPLE REGISTRATION NUMBER	IFS-250903093		
SAMPLE REGISTRATION DATE	03/09/2025		
ANALYSIS STARTING DATE	03/09/2025	ANALYSIS COMPLETION DATE	06/09/2025
SAMPLE QUANTITY RECEIVED	3 ltr in plastic bottle		
SAMPLING PROTOCOL/ METHOD	IFSG/SOP/QU/025	SAMPLE CONDITION	Good
SAMPLING DATE & TIME	02/09/2025, Time: 03:00PM		
SAMPLING LOCATION	Heritage School Sector-62, Gurgaon, Haryana		
SAMPLING DONE BY	Sample drawn by Intertek by (Mr. Narender)	REPORTING CODE	KS
OTHER INFORMATION: N/A			
SAMPLE TESTED AS RECEIVED			

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903093

ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Specification IS:10500-2012	Limit of Quantification	Method of Testing
	Chemical Parameters					
1.	Colour	Hazen	<1.0	Max 5	1	IS 3025 P-4 clause 4.0 Platinum, Cobalt (Visual Comparison) Comparison Method
2.	Odour	-	Agreeable	Agreeable	-	IS:3025 (P-5)
3.	Taste	-	Agreeable	Agreeable	-	IS:3025 (P-8)
4.	Turbidity	NTU	<1.0	Max 1.0	1.0	IS:3025 (P-10)
5.	Total Dissolved solids	mg/l	50.0	Max 500	1.0	IS:3025 (P-16)
6.	pH	-	7.22	6.5- 8.5	1.0	IS:3025 (P-11)
7.	Total Hardness (as $CaCO_3$)	mg/l	28.0	Max 200	1.0	Clause 5.0 of IS 3025 P-21
8.	Nitrate (as NO_3)	mg/l	12.61	Max 45.0	0.5	APHA 24th Ed. 4500 NO3 B
9.	Chloride (as Cl)	mg/l	12.53	Max 250	1.0	IS 3025 P-32 clause 2.0 Argentometric Method

(Authorized Signatory)
Pallavi
Sr. Analyst.

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903093

ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Requirements IS: 10500:2012	Limit of Quantification	Method of Testing
	Biological Parameters					
1.	*Escherichia coli*	/100ml	Absent	Absent	Absent	IS: 15185
2.	Coliform	/100ml	Absent	Absent	Absent	IS: 15185
3.	Standard plate count*	cfu/ml	8	-	≥1.0	IS: 1622

* Not in specification of IS: 10500:2012

Remarks1: - The submitted sample complies to 'IS 10500:2012 requirements' wherever mentioned with respect to the above parameters only.

Note: The above results pertain only to the sample tested and applicable parameter

******END OF TEST REPORT*****

(AUTHORIZED SIGNATORY)

MICROBIOLOGIST

Intertek India Pvt. Ltd., Register in India N. CIN No.: U74220DL1997PTC202243
Lab address: Plot No: 68 & 69, Udyog Vihar, Phase 1, Gurgaon -122016, Haryana, India
Tel: +91-124-484 0600, email: food.gurgaon2@intertek.com
intertek.com/india/

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903094

FOOD SERVICES
TEST REPORT

CLIENT/ISSUED TO	ANALYSIS REPORT NO.	IFS-250903094
Blue Circle Medi Services Pvt Ltd.	REPORT ISSUE DATE:	08/09/2025
J-33, Sarita Vihar	YOUR REF:	TRF
New Delhi-76	DATED:	02/09/2025
	ULR NO:	TC643425000035248F

PRODUCT GROUP:	Water

DETAILS PROVIDED BY CUSTOMER:	
NAME OF THE PRODUCT	Drinking Water
SAMPLE DETAILS	Sample code: SYS0987, Sampling Point: SP-1
TEST REQUIRED	Chemical and Biological Test
ANY OTHER INFORMATION	N/A

LAB INFORMATION:			
SAMPLE REGISTRATION NUMBER	IFS-250903094		
SAMPLE REGISTRATION DATE	03/09/2025		
ANALYSIS STARTING DATE	03/09/2025	ANALYSIS COMPLETION DATE	06/09/2025
SAMPLE QUANTITY RECEIVED	3 ltr in plastic bottle		
SAMPLING PROTOCOL/ METHOD	IFSG/SOP/QU/025	SAMPLE CONDITION	Good
SAMPLING DATE & TIME	02/09/2025, Time: 03:00PM		
SAMPLING LOCATION	Heritage School Sector-62, Gurgaon, Haryana		
SAMPLING DONE BY	Sample drawn by Intertek by (Mr. Narender)	REPORTING CODE	KS

OTHER INFORMATION: N/A
SAMPLE TESTED AS RECEIVED

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903094

ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Specification IS:10500-2012	Limit of Quantification	Method of Testing
	Chemical Parameters					
1.	Colour	Hazen	<1.0	Max 5	1	IS 3025 P-4 clause 4.0 Platinum, Cobalt (Visual Comparison) Comparison Method
2.	Odour	-	Agreeable	Agreeable	-	IS:3025 (P-5)
3.	Taste	-	Agreeable	Agreeable	-	IS:3025 (P-8)
4.	Turbidity	NTU	<1.0	Max 1.0	1.0	IS:3025 (P-10)
5.	Total Dissolved solids	mg/l	40.0	Max 500	1.0	IS:3025 (P-16)
6.	pH	-	7.08	6.5- 8.5	1.0	IS:3025 (P-11)
7.	Total Hardness (as $CaCO_3$)	mg/l	20.0	Max 200	1.0	Clause 5.0 of IS 3025 P-21
8.	Nitrate (as NO_3)	mg/l	11.83	Max 45.0	0.5	APHA 24th Ed. 4500 NO3 B
9.	Chloride (as Cl)	mg/l	10.60	Max 250	1.0	IS 3025 P-32 clause 2.0 Argentometric Method

Pallavi
(Authorized Signatory)
Pallavi
Sr. Analyst.

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903094

ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Requirements IS: 10500:2012	Limit of Quantification	Method of Testing
	Biological Parameters					
1.	*Escherichia coli*	/100ml	Absent	Absent	Absent	IS: 15185
2.	Coliform	/100ml	Absent	Absent	Absent	IS: 15185
3.	Standard plate count*	cfu/ml	11	-	≥1.0	IS: 1622

* Not in specification of IS: 10500:2012

Remarks1: - The submitted sample complies to 'IS 10500:2012 requirements' wherever mentioned with respect to the above parameters only.

Note: The above results pertain only to the sample tested and applicable parameter

******END OF TEST REPORT*****

(AUTHORIZED SIGNATORY)

MICROBIOLOGIST

Intertek India Pvt. Ltd., Register in India N. CIN No.: U74220DL1997PTC202243
Lab address: Plot No: 68 & 69, Udyog Vihar, Phase 1, Gurgaon -122016, Haryana, India
Tel: +91-124-484 0600, email: food.gurgaon2@intertek.com
intertek.com/india/

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903096

FOOD SERVICES
TEST REPORT

CLIENT/ISSUED TO	ANALYSIS REPORT NO.	IFS-250903096
Blue Circle Medi Services Pvt Ltd.	**REPORT ISSUE DATE:**	08/09/2025
J-33, Sarita Vihar	YOUR REF:	TRF
New Delhi-76	DATED:	02/09/2025
	ULR NO:	TC643425000035250F

PRODUCT GROUP:	**Water**

DETAILS PROVIDED BY CUSTOMER:	
NAME OF THE PRODUCT	Drinking Water
SAMPLE DETAILS	Sample code: SYS0988, Sampling Point: MP
TEST REQUIRED	Chemical and Biological Test
ANY OTHER INFORMATION	N/A

LAB INFORMATION:			
SAMPLE REGISTRATION NUMBER	IFS-250903096		
SAMPLE REGISTRATION DATE	03/09/2025		
ANALYSIS STARTING DATE	03/09/2025	ANALYSIS COMPLETION DATE	06/09/2025
SAMPLE QUANTITY RECEIVED	3 ltr in plastic bottle		
SAMPLING PROTOCOL/ METHOD	IFSG/SOP/QU/025	SAMPLE CONDITION	Good
SAMPLING DATE & TIME	02/09/2025, Time: 03:00PM		
SAMPLING LOCATION	Heritage School Sector-62, Gurgaon, Haryana		
SAMPLING DONE BY	Sample drawn by Intertek by (Mr. Narender)	REPORTING CODE	KS

OTHER INFORMATION: N/A

SAMPLE TESTED AS RECEIVED

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903096

ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Specification IS:10500-2012	Limit of Quantification	Method of Testing
	Chemical Parameters					
1.	Colour	Hazen	<1.0	Max 5	1	IS 3025 P-4 clause 4.0 Platinum, Cobalt (Visual Comparison) Comparison Method
2.	Odour	-	Agreeable	Agreeable	-	IS:3025 (P-5)
3.	Taste	-	Agreeable	Agreeable	-	IS:3025 (P-8)
4.	Turbidity	NTU	<1.0	Max 1.0	1.0	IS:3025 (P-10)
5.	Total Dissolved solids	mg/l	28.0	Max 500	1.0	IS:3025 (P-16)
6.	pH	-	6.55	6.5- 8.5	1.0	IS:3025 (P-11)
7.	Total Hardness (as $CaCO_3$)	mg/l	4.0	Max 200	1.0	Clause 5.0 of IS 3025 P-21
8.	Nitrate (as NO_3)	mg/l	7.77	Max 45.0	0.5	APHA 24th Ed. 4500 NO3 B
9.	Chloride (as Cl)	mg/l	5.78	Max 250	1.0	IS 3025 P-32 clause 2.0 Argentometric Method

(Authorized Signatory)
Pallavi
Sr. Analyst.

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903096

ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Requirements IS: 10500:2012	Limit of Quantification	Method of Testing
	Biological Parameters					
1.	*Escherichia coli*	/100ml	Absent	Absent	Absent	IS: 15185
2.	Coliform	/100ml	Absent	Absent	Absent	IS: 15185
3.	Standard plate count*	cfu/ml	13	-	≥1.0	IS: 1622

* Not in specification of IS: 10500:2012

Remarks1: - The submitted sample complies to 'IS 10500:2012 requirements' wherever mentioned with respect to the above parameters only.

Note: The above results pertain only to the sample tested and applicable parameter

******END OF TEST REPORT*****

(AUTHORIZED SIGNATORY)

MICROBIOLOGIST

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903095

FOOD SERVICES
TEST REPORT

CLIENT/ISSUED TO	ANALYSIS REPORT NO.	IFS-250903095
Blue Circle Medi Services Pvt Ltd.	REPORT ISSUE DATE:	08/09/2025
J-33, Sarita Vihar	YOUR REF:	TRF
New Delhi-76	DATED:	02/09/2025
	ULR NO:	TC643425000035249F

PRODUCT GROUP:	Water

DETAILS PROVIDED BY CUSTOMER:	
NAME OF THE PRODUCT	BOREWELL Water (RAW WATER)
SAMPLE DETAILS	Sample code: SYS0989, Sampling Point: Borewell Main Point
TEST REQUIRED	Chemical and Biological Test
ANY OTHER INFORMATION	N/A

LAB INFORMATION:			
SAMPLE REGISTRATION NUMBER	IFS-250903095		
SAMPLE REGISTRATION DATE	03/09/2025		
ANALYSIS STARTING DATE	03/09/2025	ANALYSIS COMPLETION DATE	06/09/2025
SAMPLE QUANTITY RECEIVED	3 ltr in plastic bottle		
SAMPLING PROTOCOL/ METHOD	IFSG/SOP/QU/025	SAMPLE CONDITION	Good
SAMPLING DATE & TIME	02/09/2025, Time: 03:00PM		
SAMPLING LOCATION	Heritage School Sector-62, Gurgaon, Haryana		
SAMPLING DONE BY	Sample drawn by Intertek by (Mr. Narender)	REPORTING CODE	KS

OTHER INFORMATION: N/A
SAMPLE TESTED AS RECEIVED

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903095

ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Specification IS:10500-2012	Limit of Quantification	Method of Testing
	Chemical Parameters					
1.	Colour	Hazen	<1.0	Max 5	1	IS 3025 P-4 clause 4.0 Platinum, Cobalt (Visual Comparison) Comparison Method
2.	Odour	-	Agreeable	Agreeable	-	IS:3025 (P-5)
3.	Taste	-	Agreeable	Agreeable	-	IS:3025 (P-8)
4.	Turbidity	NTU	<1.0	Max 1.0	1.0	IS:3025 (P-10)
5.	Total Dissolved solids	mg/l	350.0	Max 500	1.0	IS:3025 (P-16)
6.	pH	-	7.31	6.5- 8.5	1.0	IS:3025 (P-11)
7.	Total Hardness (as $CaCO_3$)	mg/l	190.0	Max 200	1.0	Clause 5.0 of IS 3025 P-21
8.	Nitrate (as NO_3)	mg/l	29.84	Max 45.0	0.5	APHA 24th Ed. 4500 NO3 B
9.	Chloride (as Cl)	mg/l	37.60	Max 250	1.0	IS 3025 P-32 clause 2.0 Argentometric Method

Pallavi
(Authorized Signatory)
Pallavi
Sr. Analyst.

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903095

ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Requirements IS: 10500:2012	Limit of Quantification	Method of Testing
	Biological Parameters					
1.	*Escherichia coli*	/100ml	Absent	Absent	Absent	IS: 15185
2.	Coliform	/100ml	Absent	Absent	Absent	IS: 15185
3.	Standard plate count*	cfu/ml	6	-	≥1.0	IS: 1622

* Not in specification of IS: 10500:2012

Remarks1: - The submitted sample complies to 'IS 10500:2012 requirements' wherever mentioned with respect to the above parameters only.

Note: The above results pertain only to the sample tested and applicable parameter

******END OF TEST REPORT*****

(AUTHORIZED SIGNATORY)

MICROBIOLOGIST

Intertek India Pvt. Ltd., Register in India N. CIN No.: U74220DL1997PTC202243
Lab address: Plot No: 68 & 69, Udyog Vihar, Phase 1, Gurgaon -122016, Haryana, India
Tel: +91-124-484 0600, email: food.gurgaon2@intertek.com
intertek.com/india/

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903097

FOOD SERVICES
TEST REPORT

CLIENT/ISSUED TO	**ANALYSIS REPORT NO.**	IFS-250903097
Blue Circle Medi Services Pvt Ltd.	**REPORT ISSUE DATE:**	08/09/2025
J-33, Sarita Vihar	YOUR REF:	TRF
New Delhi-76	DATED:	02/09/2025
	ULR NO:	TC643425000035251F

PRODUCT GROUP:	**Water**

DETAILS PROVIDED BY CUSTOMER:	
NAME OF THE PRODUCT	Drinking Water
SAMPLE DETAILS	Sample code: SYS0990, Sampling Point: JP
TEST REQUIRED	Chemical and Biological Test
ANY OTHER INFORMATION	N/A

LAB INFORMATION:			
SAMPLE REGISTRATION NUMBER	IFS-250903097		
SAMPLE REGISTRATION DATE	03/09/2025		
ANALYSIS STARTING DATE	03/09/2025	ANALYSIS COMPLETION DATE	06/09/2025
SAMPLE QUANTITY RECEIVED	3 ltr in plastic bottle		
SAMPLING PROTOCOL/ METHOD	IFSG/SOP/QU/025	SAMPLE CONDITION	Good
SAMPLING DATE & TIME	02/09/2025, Time: 03:00PM		
SAMPLING LOCATION	Heritage School Sector-62, Gurgaon, Haryana		
SAMPLING DONE BY	Sample drawn by Intertek by (Mr. Narender)	REPORTING CODE	KS

OTHER INFORMATION: N/A
SAMPLE TESTED AS RECEIVED

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903097

ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Specification IS:10500-2012	Limit of Quantification	Method of Testing
	Chemical Parameters					
1.	Colour	Hazen	<1.0	Max 5	1	IS 3025 P-4 clause 4.0 Platinum, Cobalt (Visual Comparison) Comparison Method
2.	Odour	-	Agreeable	Agreeable	-	IS:3025 (P-5)
3.	Taste	-	Agreeable	Agreeable	-	IS:3025 (P-8)
4.	Turbidity	NTU	<1.0	Max 1.0	1.0	IS:3025 (P-10)
5.	Total Dissolved solids	mg/l	22.0	Max 500	1.0	IS:3025 (P-16)
6.	pH	-	6.56	6.5- 8.5	1.0	IS:3025 (P-11)
7.	Total Hardness (as $CaCO_3$)	mg/l	6.0	Max 200	1.0	Clause 5.0 of IS 3025 P-21
8.	Nitrate (as NO_3)	mg/l	3.48	Max 45.0	0.5	APHA 24th Ed. 4500 NO3 B
9.	Chloride (as Cl)	mg/l	4.82	Max 250	1.0	IS 3025 P-32 clause 2.0 Argentometric Method

(Authorized Signatory)
Pallavi
Sr. Analyst.

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903097

ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Requirements IS: 10500:2012	Limit of Quantification	Method of Testing
	Biological Parameters					
1.	*Escherichia coli*	/100ml	Absent	Absent	Absent	IS: 15185
2.	Coliform	/100ml	Absent	Absent	Absent	IS: 15185
3.	Standard plate count*	cfu/ml	12	-	≥1.0	IS: 1622

* Not in specification of IS: 10500:2012

Remarks1: - The submitted sample complies to 'IS 10500:2012 requirements' wherever mentioned with respect to the above parameters only.

Note: The above results pertain only to the sample tested and applicable parameter

******END OF TEST REPORT*****

(AUTHORIZED SIGNATORY)

MICROBIOLOGIST

Intertek India Pvt. Ltd., Register in India N. CIN No.: U74220DL1997PTC202243
Lab address: Plot No: 68 & 69, Udyog Vihar, Phase 1, Gurgaon -122016, Haryana, India
Tel: +91-124-484 0600, email: food.gurgaon2@intertek.com
intertek.com/india/

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903098

FOOD SERVICES
TEST REPORT

CLIENT/ISSUED TO	ANALYSIS REPORT NO.	IFS-250903098
Blue Circle Medi Services Pvt Ltd.	REPORT ISSUE DATE:	08/09/2025
J-33, Sarita Vihar	YOUR REF:	TRF
New Delhi-76	DATED:	02/09/2025
	ULR NO:	TC643425000035252F

PRODUCT GROUP:	Water

DETAILS PROVIDED BY CUSTOMER:	
NAME OF THE PRODUCT	Drinking Water
SAMPLE DETAILS	Sample code: SYS0991, Sampling Point: CANTEEN
TEST REQUIRED	Chemical and Biological Test
ANY OTHER INFORMATION	N/A

LAB INFORMATION:			
SAMPLE REGISTRATION NUMBER	IFS-250903098		
SAMPLE REGISTRATION DATE	03/09/2025		
ANALYSIS STARTING DATE	03/09/2025	ANALYSIS COMPLETION DATE	06/09/2025
SAMPLE QUANTITY RECEIVED	3 ltr in plastic bottle		
SAMPLING PROTOCOL/ METHOD	IFSG/SOP/QU/025	SAMPLE CONDITION	Good
SAMPLING DATE & TIME	02/09/2025, Time: 03:00PM		
SAMPLING LOCATION	Heritage School Sector-62, Gurgaon, Haryana		
SAMPLING DONE BY	Sample drawn by Intertek by (Mr. Narender)	REPORTING CODE	KS

OTHER INFORMATION: N/A
SAMPLE TESTED AS RECEIVED

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903098

ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Specification IS:10500-2012	Limit of Quantification	Method of Testing
	Chemical Parameters					
1.	Colour	Hazen	<1.0	Max 5	1	IS 3025 P-4 clause 4.0 Platinum, Cobalt (Visual Comparison) Comparison Method
2.	Odour	-	Agreeable	Agreeable	-	IS:3025 (P-5)
3.	Taste	-	Agreeable	Agreeable	-	IS:3025 (P-8)
4.	Turbidity	NTU	<1.0	Max 1.0	1.0	IS:3025 (P-10)
5.	Total Dissolved solids	mg/l	27.0	Max 500	1.0	IS:3025 (P-16)
6.	pH	-	6.57	6.5- 8.5	1.0	IS:3025 (P-11)
7.	Total Hardness (as $CaCO_3$)	mg/l	4.0	Max 200	1.0	Clause 5.0 of IS 3025 P-21
8.	Nitrate (as NO_3)	mg/l	5.09	Max 45.0	0.5	APHA 24th Ed. 4500 NO3 B
9.	Chloride (as Cl)	mg/l	6.75	Max 250	1.0	IS 3025 P-32 clause 2.0 Argentometric Method

(Authorized Signatory)
Pallavi
Sr. Analyst.

intertek
Total Quality. Assured.

TC-6434

ANALYSIS REPORT NO. IFS-250903098

ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Requirements IS: 10500:2012	Limit of Quantification	Method of Testing
	Biological Parameters					
1.	*Escherichia coli*	/100ml	Absent	Absent	Absent	IS: 15185
2.	Coliform	/100ml	Absent	Absent	Absent	IS: 15185
3.	Standard plate count*	cfu/ml	15	-	≥1.0	IS: 1622

* Not in specification of IS: 10500:2012

Remarks1: - The submitted sample complies to 'IS 10500:2012 requirements' wherever mentioned with respect to the above parameters only.

Note: The above results pertain only to the sample tested and applicable parameter

******END OF TEST REPORT*****

(AUTHORIZED SIGNATORY)

MICROBIOLOGIST

Intertek India Pvt. Ltd., Register in India N. CIN No.: U74220DL1997PTC202243
Lab address: Plot No: 68 & 69, Udyog Vihar, Phase 1, Gurgaon -122016, Haryana, India
Tel: +91-124-484 0600, email: food.gurgaon2@intertek.com
intertek.com/india/